DEP—LEAD AND COPPER ANALYSIS REPORT LCR-C

PWS ID# 1275000 PWS NAME South Hadley FD #1 TOWN South Hadley SAMPLE CODE*

NAME OF STATE CERTIFIED LABORATORY MWRA / Department of Lab Services CERTIFIED LABORATORY ID# M-MA153

LEAD ANALYSIS METHOD 200.9 LEAD DETECTION LIMIT 0.0012 mg/L COPPER ANALYSIS METHOD 200.7 COPPER DETECTION LIMIT 0.003 mg/L

OF SAMPLES REQUIRED* 60 # OF SAMPLES SUBMITTED* 60 90TH PERCENTILE LEAD* 0.00939 90TH PERCENTILE COPPER* 0.0279

	Lab ID Sample	Collection Date	DEP Approved Sample Site	Lead Result mg/L	Lead Analysis Date	Copper Result mg/L	Copper Analysis Date
1	07005286	02/13/07	24 ALVORD ST	0.00128	3/2/07	0.01480	2/23/07
2	07005287	02/14/07	26 ALVORD ST	0.01030	3/2/07	0.04130	2/23/07
3	07005288	02/13/07	67 ALVORD ST	0.00269	3/2/07	0.02790	2/23/07
4	07005289	02/13/07	11 ASHTON LN	0.00000	3/2/07	0.00488	2/23/07
5	07005290	02/13/07	26 ASHTON LN	0.00220	3/2/07	0.00887	2/23/07
6	07005291	02/13/07	29 ASHTON LN	0.00786	3/2/07	0.00877	2/23/07
7	07005292	02/13/07	1 BLUEBERRY BEND	0.00773	3/2/07	0.00000	2/23/07
8	07005293	02/13/07	7 BLUEBERRY BEND	0.00939	3/2/07	0.00898	2/23/07
9	07005294	02/13/07	11 BLUEBERRY BEND	0.00759	3/2/07	0.01560	2/23/07
10	07005295	02/13/07	12 BLUEBERRY BEND	0.00000	3/2/07	0.01130	2/23/07
11	07005296	02/13/07	15 BLUEBERRY BEND	0.00170	3/2/07	0.01740	2/23/07
12	07005297	02/13/07	288 BRAINERD ST	0.00152	3/2/07	0.00706	2/23/07
13	07005298	02/13/07	292 BRAINERD ST	0.00241	3/2/07	0.00340	2/23/07
14	07005299	02/14/07	296 BRAINERD ST	0.00000	3/2/07	0.00000	2/23/07
15	07005300	02/13/07	76 CAMDEN ST	0.07290	3/2/07	0.03340	2/23/07
16	07005301	02/13/07	6 CRYSTAL LN	0.00000	3/2/07	0.00308	2/23/07
17	07005302	02/13/07	27 DALE ST	0.00000	3/2/07	0.00000	2/23/07
18	07005303	02/13/07	29 DALE ST	0.00000	3/2/07	0.00379	2/23/07
19	07005304	02/16/07	29 1/2 DALE STREET	0.00158	3/2/07	0.00788	3/1/07
20	07005305	02/13/07	184 EAST ST. (GRANBY)	0.00267	3/2/07	0.00495	2/23/07
21	07005306	02/13/07	186 EAST ST. (GRANBY)	0.00581	3/2/07	0.01460	2/23/07
22	07005307	02/13/07	188 EAST ST. (GRANBY)	0.00372	3/2/07	0.01490	2/23/07
23	07005308	02/16/07	230 EAST STREET GRANBY	0.00474	3/2/07	0.02000	3/1/07
24	07005309	02/13/07	4 FAIRMONT ST	0.00134	3/2/07	0.01140	2/23/07
25	07005310	02/13/07	587 FULLER ST, LUDLOW	0.00288	3/2/07	0.05050	2/23/07
26	07005311	02/13/07	2 GLEN ST	0.00000	3/2/07	0.00694	2/23/07
27	07005312	02/13/07	283 GRANBY RD	0.00784	3/2/07	0.01160	2/23/07
28	07005313	02/13/07	589 GRANBY RD	0.00000	3/2/07	0.00553	2/23/07
29	07005314	02/13/07	6 HENRY RD	0.00000	3/2/07	0.00000	2/23/07
30	07005315	02/13/07	24 HIGHLAND AVE	0.00598	3/2/07	0.01460	2/23/07
31	07005316	02/14/07	32 HIGHLAND AVE	0.00186	3/2/07	0.06170	2/23/07
32	07005317	02/13/07	12 JOFFRE AVE	0.00000	3/2/07	0.00698	2/23/07
33	07005318	02/14/07	18 KIMBERLY DR	0.00000	3/2/07	0.01890	2/23/07
34	07005319	02/13/07	105 LANTHROP ST	0.00209	3/2/07	0.00619	2/23/07
35	07005320	02/13/07	172 LANTHROP ST	0.00000	3/2/07	0.00000	2/23/07
36	07005321	02/13/07	71 LINCOLN ST	0.00445	3/2/07	0.00743	2/23/07
37	07005322	02/15/07	64 MCKINLEY AVE	0.00196	3/2/07	0.01370	2/23/07
38	07005323	02/13/07	351 NEWTON ST	0.00127	3/2/07	0.00000	2/23/07
39	07005324	02/16/07	231 NORTH MAIN STREET	0.00000	3/2/07	0.02670	3/1/07
40	07005325	02/14/07	1 PHEASANT RUN	0.00742	3/2/07	0.01950	2/23/07
41	07005326	02/14/07	2 PHEASANT RUN	0.00000	3/2/07	0.00000	2/23/07

42	07005327	02/13/07	6 PHEASANT RUN	0.00000	3/2/07	0.01080	2/23/07
43	07005328	02/20/07	16 PHEASANT RUN	0.00972	3/2/07	0.01900	3/1/07
44	07005329	02/14/07	11 PITROFF AVE	0.00240	3/2/07	0.04460	2/23/07
45	07005330	02/13/07	13 PITROFF AVE	0.00144	3/2/07	0.01390	2/23/07
46	07005331	02/14/07	46 RICHVIEW AVE	0.00362	3/2/07	0.01450	2/23/07
47	07005332	02/21/07	39 ROOSEVELT AVENUE	0.00000	3/2/07	0.00615	3/1/07
48	07005333	02/13/07	3 SKYLINE DR	0.00000	3/2/07	0.00000	2/23/07
49	07005334	02/13/07	19 SOUTH ST	0.00573	3/2/07	0.01040	2/23/07
50	07005335	02/13/07	45 VIVANNI ST	0.02690	3/2/07	0.01160	2/23/07
51	07005336	02/13/07	41 W. SUMMIT ST UNIT #20	0.00000	3/2/07	0.01100	2/23/07
52	07005337	02/15/07	43 W. SUMMIT ST UNIT # 4	0.00124	3/2/07	0.00452	2/23/07
53	07005338	02/14/07	43 W. SUMMIT ST UNIT # 8	0.07890	3/2/07	0.07170	2/23/07
54	07005339	02/13/07	43 W. SUMMIT ST UNIT # 10	0.01720	3/2/07	0.01340	2/23/07
55	07005340	02/14/07	43 W. SUMMIT ST UNIT # 11	0.00627	3/2/07	0.01370	2/23/07
56	07005341	02/14/07	43 W. SUMMIT ST UNIT # 12	0.00394	3/2/07	0.02370	2/23/07
57	07005342	02/15/07	43 W. SUMMIT ST UNIT # 14	0.00230	3/2/07	0.00914	2/23/07
58	07005343	02/13/07	43 W. SUMMIT ST UNIT # 16	0.00712	3/2/07	0.02060	2/23/07
59	07005344	02/14/07	43 W. SUMMIT ST UNIT # 20	0.00271	3/2/07	0.00626	2/23/07
60	07005345	02/16/07	47 WILD WOOD LANE	0.00314	3/2/07	0.01950	3/1/07

	Lab ID Sample	Collection Date	DEP Approved Sample Site	Lead Result mg/L	Lead Analysis Date	Copper Result mg/L	Copper Analysis Date
	SCHOOL RESULTS collected in accordance with 310 MCR 22.06B (7) (a) 9. Do not use these schools in the 90th percentile calculations. (PWS must attach laboratory reports for schools to this form)						
1	07005346	02/16/07	PVPA 15 MULLIGAN DRIVE BUBBLER	0.00000	3/2/07	0.36400	3/1/07
2	07005347	02/16/07	PVPA 15 MULLIGAN DRIVE KITCHEN	0.00000	3/2/07	0.02270	3/1/07
3	07005348	02/13/07	CRITERION DAYCARE CENTER BUBBLER	0.00000	3/2/07	0.04410	2/23/07
4	07005349	02/13/07	CRITERION DAYCARE CENTER KITCHEN	0.00000	3/2/07	0.03010	2/23/07

SAMPLE CODE		PLEASE NOTE THE FOLLOWING:
1	FIRST SAMPLING PERIOD	WATER SUPPLIERS SHOULD MAIL ONE COPY OF THIS FORM, including all results for monitoring period, TO THE DEP REGIONAL OFFICE WITHIN 10 DAYS AFTER THE END OF THE REPORTING PERIOD.
2	SECOND SAMPLING PERIOD	** SEE DEP LEAD & COPPER SAMPLING PLAN FOR APPROVED SAMPLING LOCATIONS.
3	REDUCED – ANNUAL	*** Results below the laboratory's reported detection limit (MDL) shall be reported as zero. Results at or above the laboratory's detection limit (MDL) but below 0.005 mg/L for lead or 0.05 mg/L for copper shall be reported as measured or may be reported as 0.0025 mg/L for lead and 0.025 mg/L for copper.
4	REDUCED - EVERY THREE YEARS	
5	LSL REPLACEMENT PROGRAM	
6	DEMONSTRATION	Please submit Forms **LCR-D** or **LCR-E** to the appropriate DEP Regional Office along with this form.

REMARKS:_____

Michael F. Delaney — 3/14/07

SIGNATURE OF PWS or LABORATORY DIRECTOR — DATE

DEP—LEAD AND COPPER ANALYSIS REPORT

LCR-C

PWS ID# 1275000 PWS NAME South Hadley FD #1 TOWN South Hadley SAMPLE CODE*

NAME OF STATE CERTIFIED LABORATORY MWRA / Department of Lab Services CERTIFIED LABORATORY ID# M-MA153

LEAD ANALYSIS METHOD 200.9 LEAD DETECTION LIMIT 0.0012 mg/L COPPER ANALYSIS METHOD 200.7 COPPER DETECTION LIMIT 0.003 mg/L

OF SAMPLES REQUIRED* 30 # OF SAMPLES SUBMITTED* 30 90TH PERCENTILE LEAD* 0.0107 90TH PERCENTILE COPPER* 0.0218

	Lab ID Sample	Collection Date	DEP Approved Sample Site	Lead Result mg/L	Lead Analysis Date	Copper Result mg/L	Copper Analysis Date
1	08037654	06/11/08	4 FAIRMONT AVE	0.00722	06/27/08	0.0153	06/20/08
2	08037655	06/11/08	587 FULLER ST	<0.0012	06/27/08	0.0134	06/20/08
3	08037656	06/11/08	71 LINCOLN AVE	0.00181	06/27/08	0.007	06/20/08
4	08037657	06/11/08	7 BLUEBERRY BEND	0.00317	06/27/08	0.0112	06/20/08
5	08037658	06/11/08	283 GRANBY RD	0.00476	06/27/08	0.010	06/20/08
6	08037659	06/11/08	296 BRAINERD ST	<0.0012	06/27/08	<0.003	06/20/08
7	08037660	06/11/08	11 BLUEBERRY	0.00147	06/27/08	0.0112	06/20/08
8	08037661	06/11/08	230 EAST GRANBY	0.0111	06/27/08	0.0132	06/20/08
9	08037662	06/11/08	12 BLUEBERRY BEND	<0.0012	06/27/08	0.0139	06/20/08
10	08037663	06/11/08	1 PHEASANT RUN	0.00267	06/27/08	0.0115	06/20/08
11	08037664	06/11/08	43 W SUMMIT #4	<0.0012	06/27/08	0.00896	06/20/08
12	08037665	06/11/08	6 CRYSTAL LN	0.00332	06/27/08	0.0218	06/20/08
13	08037666	06/11/08	43 WEST SUMMIT APT 8	0.00819	06/27/08	0.0414	06/20/08
14	08037667	06/11/08	24 HIGHLAND AVE	0.0107	06/27/08	0.0134	06/20/08
15	08037668	06/11/08	43 WEST SUMMIT APT 16	0.00571	06/27/08	0.0165	06/20/08
16	08037669	06/11/08	2 GLEN ST	0.00133	06/27/08	0.0119	06/20/08
17	08037670	06/11/08	26 ASHTON LN	0.00183	06/27/08	0.00903	06/20/08
18	08037671	06/13/08	64 MCKINLEY AVE	0.00273	06/27/08	0.0153	06/26/08
19	08037672	06/12/08	172 LANTHROP ST	<0.0012	06/27/08	0.00423	06/26/08
20	08037673	06/12/08	45 VIVIANI ST	0.0127	06/27/08	0.0125	06/26/08
21	08037674	06/11/08	589 GRANBY RD	0.00193	06/27/08	0.0207	06/26/08
22	08037675	06/12/08	24 ALVORD ST	0.0240	06/27/08	0.0234	06/26/08
23	08037676	06/12/08	184 EAST ST	0.00594	06/27/08	0.0165	06/26/08
24	08037677	06/12/08	26 ALVORD ST	0.00408	06/27/08	0.0195	06/26/08
25	08037678	06/16/08	43 WEST SUMMIT ST., APT. 20	0.00368	06/27/08	0.0195	06/26/08
26	08037679	06/13/08	46 RICHVIEW AVE.	0.00453	06/27/08	0.0197	06/26/08
27	08037680	06/12/08	29 1/2 DALE ST.	<0.0012	06/27/08	0.00452	06/26/08
28	08037681	06/16/08	231 NORTH MAIN	<0.0012	06/27/08	0.00426	06/26/08
29	08037682	06/16/08	6 HENRY ROAD	<0.0012	06/27/08	<0.003	06/26/08
30	08037683	06/25/08	43 W. SUMMIT STREET,14	0.00401	06/27/08	0.0226	07/07/08

	Lab ID Sample	Collection Date	DEP Approved Sample Site	Lead Result mg/L	Lead Analysis Date	Copper Result mg/L	Copper Analysis Date
	SCHOOL RESULTS collected in accordance with 310 MCR 22.06B (7) (a) 9. Do not use these schools in the 90th percentile calculations. (PWS must attach laboratory reports for schools to this form)						
1	08037684	06/11/08	PLAINS SCHOOL FOUNTAIN	<0.0012	06/27/08	0.00708	06/20/08
2	08037685	06/11/08	PLAINS SCHOOL KITCHEN	0.00361	06/27/08	0.0385	06/20/08
3	08037686	06/11/08	BRIGHTER BEGINNINGS FOUNTAIN	<0.0012	06/27/08	0.048	06/20/08
4	08037687	06/11/08	BRIGHTER BEGINNINGS KITCHEN	0.00696	06/27/08	0.0232	06/20/08

Massachusetts Department of Environmental Protection - Drinking Water Program **LCR-C**

Lead and Copper Analysis Report

I. PWS INFORMATION: Please refer to your DEP Lead & Copper sampling plan for approved sampling locations.

PWS ID #: 1275000 **City / Town:** South Hadley

PWS Name: South Hadley FD #1 **PWS Class:** COM ☒ NTNC ☐ TNC ☐

Routine or Special Samples	Original, Resubmitted or Confirmation Report	If Resubmitted Report, list below:	
		(1) Reason for Resubmission	(2) Collection Date of Original Sample
☒ RS ☐ SS	☒ Original ☐ Resubmitted ☐ Confirmation	☐ Resample ☐ Reanalysis ☐ Report Correction	

SAMPLE NOTES – (Such as, if a Manifold/Multiple sample, list the sources that were on-line during sample collection).

II. ANALYTICAL LABORATORY INFORMATION:

Primary Lab MA Cert. #: M-MA153 **Primary Lab Name:** MWRA/Dept. Of Lab Services **Subcontracted? (Y/N)** N

Analyte	Action Level (mg/L)	Lab Method	MDL (mg/L)	Analysis Lab MA Cert.#	Analysis Lab Name
Lead:	0.015	200.9	0.0012	M-MA153	MWRA/Dept. of Lab Services
Copper:	1.3	200.7	0.0030	M-MA153	MWRA/Dept. of Lab Services

LAB SAMPLE NOTES

	DEP Approved Sample Location (See DEP approved LCR plan for sampling locations)	Collection Date	LEAD		COPPER		Lab Sample ID#
			Result (mg/L)	Date Analyzed	Result (mg/L)	Date Analyzed	
1	45 VIVIANI ST	06/10/09	0.111	7/1/2009	0.114	06/30/09	09036970
2	7 BLUEBERRY BEND	06/10/09	0.005	7/1/2009	0.0114	06/30/09	09036971
3	2 GLEN ST	06/10/09	0	7/1/2009	0.00648	06/30/09	09036972
4	4 FAIRMONT AVE	06/10/09	0	7/1/2009	0.0135	06/30/09	09036973
5	230 EAST ST	06/10/09	0	7/1/2009	0.0144	06/30/09	09036974
6	24 HIGHLAND AVE	06/10/09	0.00425	7/1/2009	0.0117	06/30/09	09036975
7	43 WEST SUMMIT ST UNIT 8	06/10/09	0.00158	7/1/2009	0.033	06/30/09	09036976
8	71 LINCOLN AVE	06/10/09	0	7/1/2009	0.00665	06/30/09	09036977
9	29 1/2 DALE ST	06/10/09	0.00447	7/1/2009	0.0101	06/30/09	09036978
10	11 BLUEBERRY BD	06/10/09	0.00193	7/1/2009	0.0145	06/30/09	09036979
11	43 WEST SUMMIT ST UNIT 14	06/17/09	0	7/1/2009	0.0148	06/30/09	09036980
12	26 ASHTON LN	06/10/09	0	7/1/2009	0.00938	06/30/09	09036981
13	589 GRANBY ROAD	06/10/09	0.00336	7/1/2009	0.0427	06/30/09	09036982
14	46 RICHVIEW AVE	06/11/09	0.00163	7/1/2009	0.0183	06/30/09	09036983
15	64 MCKINLEY AVE	06/12/09	0.00236	7/1/2009	0.012	06/30/09	09036984
16	43 WEST SUMMIT ST UNIT 20	06/11/09	0.00632	7/1/2009	0.0602	06/30/09	09036985
17	296 BRAINERD ST	06/16/09	0.004	7/1/2009	0.0148	06/30/09	09036986
18	172 LATHROP ST	06/11/09	0	7/1/2009	0.00639	06/30/09	09036987
19	6 CRYSTAL LN	06/10/09	0.00225	7/1/2009	0.0226	06/30/09	09036988
20	1 PHEASANT RUN	06/12/09	0	7/1/2009	0.00828	06/30/09	09036989
21	26 ALVORD ST	06/15/09	0.0183	7/1/2009	0.0283	06/30/09	09036990
22	43 WEST SUMMIT ST UNIT 4	06/10/09	0	7/1/2009	0.00466	06/30/09	09036991
23	231 N MAIN	06/10/09	0	7/1/2009	0.017	06/30/09	09036992
24	283 GRANBY ROAD	06/10/09	0.00155	7/1/2009	0.00671	06/30/09	09036993
25	24 ALVORD ST	06/10/09	0.00201	7/1/2009	0.0231	06/30/09	09036994
26	184 EAST ST	06/10/09	0.0266	7/1/2009	0.0188	06/30/09	09036995
27	43 WEST SUMMIT ST UNIT 16	06/10/09	0.00782	7/1/2009	0.0116	06/30/09	09036996
28	587 FULLER ST	06/10/09	0	7/1/2009	0.0173	06/30/09	09036997
29	6 HENRY RD	06/10/09	0	7/1/2009	0.00597	06/30/09	09036998
30	12 BLUEBERRY BEND	06/10/09	0	7/1/2009	0.0162	07/10/09	09036999

Massachusetts Department of Environmental Protection - Drinking Water Program **LCR-C**

Lead and Copper Analysis Report

Report SCHOOL RESULTS collected in accordance with 310 CMR 22.06B (7)(a)9 below. Do not use these school results in 90th percentile calculations.							
1	SOUTH HADLEY HIGH SCHOOL	06/10/09	0.00148	7/1/2009	0.0808	06/30/09	09037000
2	SOUTH HADLEY HIGH SCHOOL	06/10/09	0	7/1/2009	0.0183	06/30/09	09037001
3	CANAL VILLAGE SCHOOL KTCHEN	06/10/09	0.00365	7/1/2009	0.014	07/10/09	09037002
4	CANAL VILLAGE SCHOOL FOUNTAIN	06/10/09	0.0045	7/1/2009	0.0208	06/30/09	09037003

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Primary Lab Director Signature: Michael F. Delaney

Date: 7/21/2009

If not submitting these results electronically, mail ONE copy of this report to your DEP Regional Office no later than 10 days after the end of the month in which you received this report or no later than 10 days after the end of the reporting period, whichever is sooner.

COM & NTNC Public Water Suppliers must submit Forms **LCR-D** or **LCR-E** with this form to the appropriate DEP Regional Office.

DEP REVIEW STATUS (Initial & Date)	Review Comments	
☐ Accepted _____ ☐ Disapproved _____		

Massachusetts Department of Environmental Protection - Drinking Water Program **LCR-C**

Lead and Copper Analysis Report

I. PWS INFORMATION: Please refer to your DEP Lead & Copper sampling plan for approved sampling locations.

PWS ID #: 127500 **City / Town:** South Hadley

PWS Name: South Hadley, Fd#1 **PWS Class:** COM ☒ NTNC ☐ TNC ☐

Routine or Special Samples	Original, Resubmitted or Confirmation Report	If Resubmitted Report, list below:	
		(1) Reason for Resubmission	(2) Collection Date of Original Sample
☒ RS ☐ SS	☒ Original ☐ Resubmitted ☐ Confirmation	☐ Resample ☐ Reanalysis ☐ Report Correction	

SAMPLE NOTES – (Such as, if a Manifold/Multiple sample, list the sources that were on-line during sample collection).

II. ANALYTICAL LABORATORY INFORMATION:

Primary Lab MA Cert.#: M-MA153 Primary Lab Name: MWRA / Department Of Lab Services Subcontracted? (Y/N) N

Analyte	Action Level (mg/L)	Lab Method	MDL (mg/L)	Analysis Lab MA Cert.#	Analysis Lab Name
Lead:	0.015	200.8	0.00005	M-MA153	MWRA / Department of Lab Services
Copper:	1.3	200.8	0.0002	M-MA153	MWRA / Department of Lab Services

LAB SAMPLE NOTES

	DEP Approved Sample Location (See DEP approved LCR plan for sampling locations)	Collection Date	LEAD		COPPER		Lab Sample ID#
			Result (mg/L)	Date Analyzed	Result (mg/L)	Date Analyzed	
1	230 East st	6/4/2013	0.00426	6/18/2013	0.0146	6/18/2013	2969140
2	283 Granby Rd	6/4/2013	0.00209	6/18/2013	0.00401	6/18/2013	2969141
3	1 Pheasant Run	6/6/2013	0.000949	6/18/2013	0.00709	6/18/2013	2969142
4	46 Richview Ave	6/4/2013	0.00319	6/18/2013	0.0187	6/18/2013	2969143
5	24 Alvord St	6/4/2013	0.00204	6/18/2013	0.0172	6/18/2013	2969144
6	43 west Summit St Apt 8	6/4/2013	0.00263	6/18/2013	0.0301	6/18/2013	2969145
7	4 Fairmont Ave	6/4/2013	0.0553	6/25/2013	0.0185	6/25/2013	2969146
8	43 W. Summit #4	6/4/2013	0.000774	6/18/2013	0.00657	6/18/2013	2969147
9	12 Blueberry bend	6/5/2013	0.000326	6/18/2013	0.0147	6/18/2013	2969148
10	589 Granby Rd	6/4/2013	0.00037	6/18/2013	0.0511	6/18/2013	2969149
11	43 W. Summit #16	6/4/2013	0.00253	6/18/2013	0.0123	6/18/2013	2969150
12	2 Glen st	6/4/2013	0.000359	6/18/2013	0.00336	6/18/2013	2969151
13	45 Viviani st	6/4/2013	0.00541	6/18/2013	0.0213	6/18/2013	2969155
14	6 Crystal Lane	6/4/2013	0.029	6/18/2013	0.0342	6/18/2013	2969156
15	11 Blueberry Bend	6/4/2013	0.00126	6/18/2013	0.00894	6/18/2013	2969158
16	24 Highland Ave	6/4/2013	0.00396	6/18/2013	0.0123	6/18/2013	2969159
17	26 Alvord St	6/5/2013	0.00252	6/18/2013	0.0206	6/18/2013	2969160
18	13 Pheasant Run	6/4/2013	0.0000813	6/18/2013	0.00442	6/18/2013	2969163
19	296 Brainerd St	6/4/2013	0.000256	6/18/2013	0.00613	6/18/2013	2969164
20	6 Henry Rd	6/4/2013	0.000641	6/18/2013	0.00364	6/18/2013	2969166
21	7 Lincoln Ave	6/4/2013	0.00102	6/18/2013	0.00644	6/18/2013	2969167
22	172 Lathrop St	6/4/2013	0.000156	6/18/2013	0.00516	6/18/2013	2969168
23	43 W. Summit st #14	6/6/2013	0.0006	6/18/2013	0.00921	6/18/2013	2969169
24	43 W. Summit St #20	6/4/2013	0.00121	6/18/2013	0.0176	6/18/2013	2969173
25	26 Ashton Lane	6/4/2013	0.00131	6/18/2013	0.0123	6/18/2013	2969174
26	23 North Main	6/4/2013	0.00501	6/18/2013	0.016	6/18/2013	2969175
27	7 Blueberry bend	6/4/2013	0.0193	6/18/2013	0.0585	6/18/2013	2969176
28	587 Fuller St	6/4/2013	0.000323	6/18/2013	0.0184	6/18/2013	2969177
29	29 1/2 Dale St	6/4/2013	0.00189	6/18/2013	0.0162	6/18/2013	2969178
30	64 McKinley Ave	6/5/2013	0.00102	6/18/2013	0.0138	6/18/2013	2969180

Massachusetts Department of Environmental Protection - Drinking Water Program **LCR-C**

Lead and Copper Analysis Report

Report SCHOOL RESULTS collected in accordance with 310 CMR 22.06B (7)(a)9 below. Do not use these school results in 90th percentile calculations.							
1	South Hadley High School Bubbler	6/4/2013	0.000298	6/18/2013	0.0128	6/18/2013	2969136
2	South Hadley High School faucet	6/4/2013	0.000298	6/18/2013	0.0261	6/18/2013	2969137
3	Criterion Day Care Bubbler	6/4/2013	0.000784	6/18/2013	0.0711	6/18/2013	2969138
4	Criterion Day Care faucet	6/4/2013	0.000284	6/18/2013	0.0467	6/18/2013	2969139

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Primary Lab Director Signature: Michael F. Delaney

Date: 7/9/2013

If not submitting these results electronically, mail ONE copy of this report to your DEP Regional Office no later than 10 days after the end of the month in which you received this report or no later than 10 days after the end of the reporting period, whichever is sooner.

COM & NTNC Public Water Suppliers must submit Forms **LCR-D or LCR-E** with this form to the appropriate DEP Regional Office.

DEP REVIEW STATUS (Initial & Date)	Review Comments	
☐ Accepted _____ ☐ Disapproved _____		